



150001283373



(2018)国认监认字(531)号



中国认可
国际互认
检测
TESTING
CNAS L1449

检测报告

TEST REPORT

报告编号: FH2020YB0425



样品名称: IXPE电子交联保温管

Sample Name

委托单位: 湖北金菲科技有限公司

Applicant

检测类别: 委托检测

Test Type

国家建筑防火产品安全质量监督检验中心

National Center for Safety Quality Supervision and Testing of Fire-proof Building Products



国家建筑防火产品安全质量监督检验中心

检测报告 (TEST REPORT)



报告编号№: FH2020YB0425

本报告正文第 1 页 共2 页

委托单位 Applicant	上海微熙工贸有限公司	检测类别 Test Type	委托检测
受检单位 Inspected Entity	上海微熙工贸有限公司	收样日期 Receive Date	2020年07月03日
工程名称及使用部位 Engineering Name and Application Part	——	检测日期 Test Date	2020年07月03日至2020年07月13日
样品名称 Sample Name	IXPE电子交联保温管	样品数量 Sample Quantity	3m
型号/规格 Type/Specification	DN16	样品等级 Grade	——
生产单位 Manufacturer	上海微熙工贸有限公司	样品状态 Sample State	管状
生产日期/批号 Production Date/Lot №	——	商标 Trade Mark	FINER (菲耐)
检测依据 Ref Documents	详见数据页		
判定依据 Decision Documents	——		
检测项目 Test Item	拉伸强度, 断裂伸长率, 导热系数		
检测结论 Test Conclusion	该样品经检测, 其检测项目检测结果见数据页。 签发日期: 2020年07月14日 Issued by (Stamp)		
附注 Remarks	本检测结果仅对收到的样品有效。 检测专用章		

批 准: 李素艳
Approved by:审 核: 刘佳
Inspected by:主 检: 杨明
Tested by:

国家建筑防火产品安全质量监督检验中心
检 测 报 告 (TEST REPORT)

报告编号№: FH2020YB0425 本报告正文第 2 页 共2 页

序号	检测项目	检测依据	检测结果
1	拉伸强度, kPa	GB/T 6344-2008	507
2	导热系数, W/(m·K)	GB/T 10297-2015	0.052
3	断裂伸长率, %	GB/T 6344-2008	141

检测地址: 北京市房山区窦店镇亚新路17号;
联系电话: 400330789、010-60344954。
(本页以下空白)

***** 结 束 *****

注意事项 NOTICE

1.报告无“检验检测专用章”或检测单位公章、骑缝章无效。

Test report is invalid without the "special seal for test report" or that of test department and perforated rider stamp on it.

2.不得部分复制本报告；复制报告未重新加盖“检验检测专用章”或检测单位公章无效。

Parts of a report are not taken out of context; duplication of test report is invalid without the "special seal for test report" or that of test department re-stamped on it.

3.报告无主检、审核、批准签字无效。

Test report is invalid without the signatures of the persons for chief test, verification and approval.

4.报告涂改无效。


Test report is invalid if altered.

5.对检测报告若有异议，应于收到报告之日起十五日内向检测单位提出。

Any dissidence about the test report should be brought forward to the test department within 15 days from the date of receiving the test report.

6.一般情况，委托检测仅对收到的样品负责。

In general, for entrusted tests the responsibilities are undertaken for the delivered samples only.



路线备注：沿阜石路高架向西行驶，见金顶西街出口进入辅路，金安桥下右转，第二个丁字路口（第一个红绿灯）右转，直行 600 米路北。



地址：北京市石景山区金顶北路69号(100041)

Add: No. 69 Jin Ding North Road, Shijingshan District, Beijing, China 100041

网址(Web): www.bmtbj.cn

电话(Tel): 010-88724984 88749821

传真(Fax): 010-88715189

客服热线: 400-0330-789