



170002283545



(2020) 国认监认字(603) 号



中国认可
国际互认
检测
TESTING
CNAS L1449

检 测 报 告

TEST REPORT

报告编号: JS2020GD3493



样品名称: 对接铝塑复合管

Sample Name

委托单位: 湖北金菲科技有限公司

Applicant

检测类别: 委托检测

Test Type

国家节水器具产品质量监督检验中心

National Center for Quality Supervision and Testing of Water-saving Appliances

检验检测专用章

国家节水器具产品质量监督检验中心



检测报告 (TEST REPORT)

本报告正文第 1 页 共2 页

报告编号№: JS2020GD3493

委托单位 Applicant	湖北金菲科技有限公司	检测类别 Test Type	委托检测
受检单位 Inspected Entity	湖北金菲科技有限公司	收样日期 Receive Date	2020年12月21日
工程名称及使用部位 Engineering Name and Application Part	——	检测日期 Test Date	2021年01月26日至2021年01月29日
样品名称 Sample Name	对接铝塑复合管	样品数量 Sample Quantity	6米
型号/规格 Type/Specification	16×2.0, PEX	样品等级 Grade	——
生产单位 Manufacturer	湖北金菲科技有限公司	样品状态 Sample State	管状
生产日期/批号 Production Date/Lot №	——	商标 Trade Mark	FINER(菲耐)
检测依据 Ref Documents	详见数据页		
判定依据 Decision Documents	CJ/T 159-2015《铝塑复合压力管（对接焊）》		
检测项目 Test Item	外观，尺寸，管环径向拉力性能，1h静液压强度试验		
检测结论 Test Conclusion	该样品经检测，所检项目中尺寸检验结果见数据页，其余项目符合CJ/T 159-2015《铝塑复合压力管（对接焊）》的指标要求。 签发日期：2021年02月02日 (Issued by Stamp)		
附注 Remarks	1. 本检测结果仅对收到的样品负责。 2. $\Phi 16 \times 2.0$ 为非标准尺寸，故尺寸测量结果不作判定。		

批准：
Approved by:

李延军

审核：
Inspected by:

周峰

主检：
Tested by:

冯解源

国家节水器具产品质量监督检验中心

检 测 报 告 (TEST REPORT)

本报告正文第 2 页 共2 页

报告编号№: JS2020GD3493

序号	检测项目		检测依据	指标要求	检测结果	单项判定
1	外观		CJ/T 159-2015	铝塑复合管表面应清洁、光滑, 不应有气泡、明显的划伤、凹陷、杂质、表面颜色不均匀等缺陷。	铝塑复合管表面清洁、光滑, 无气泡、明显的划伤、凹陷、杂质、表面颜色不均匀等缺陷。	符合
2	尺寸, mm	外径	CJ/T 159-2015	—	16.1~16.2	—
		管壁厚	CJ/T 159-2015	—	2.1~2.3	—
		内层塑料厚	CJ/T 159-2015	—	1.2	—
		外层塑料最小壁厚	CJ/T 159-2015	—	0.7~0.8	—
		铝管层壁厚	CJ/T 159-2015	—	0.3	—
3	管环径向拉力性能, N		GB/T 18997.1-2003	≥ 2400	2794	符合
4	1h静液压强度试验		GB/T 6111-2018	应无破裂、无局部球形膨胀、无渗漏	无破裂、无局部球形膨胀、无渗漏	符合

检测地址: 北京市房山区窦店镇亚新路17号;

联系电话: 4000330789、010-60344954。

(本页以下空白)

***** 结 束 *****

注意事项

NOTICE

1.报告无“检验检测专用章”或检测单位公章、骑缝章无效。

Test report is invalid without the "special seal for test report" or that of test department and perforated rider stamp on it.

2.不得部分复制本报告；复制报告未重新加盖“检验检测专用章”或检测单位公章无效。

Parts of a report are not taken out of context; duplication of test report is invalid without the "special seal for test report" or that of test department re-stamped on it.

3.报告无主检、审核、批准签字无效。

Test report is invalid without the signatures of the persons for chief test, verification and approval.

4.报告涂改无效。

Test report is invalid if altered.

5.对检测报告若有异议，应于收到报告之日起十五日内向检测单位提出。

Any dissidence about the test report should be brought forward to the test department within 15 days from the date of receiving the test report.

6.一般情况，委托检测仅对收到的样品负责。

In general, for entrusted tests the responsibilities are undertaken for the delivered samples only.



路线备注：沿阜石路高架向西行驶，见金顶西街出口进入辅路，金安桥下右转，第二个丁字路口（第一个红绿灯）右转，直行600米路北。



地址：北京市石景山区金顶北路69号(100041)

Add: No. 69 Jin Ding North Road, Shijingshan District, Beijing, China 100041

网址(Web): www.bmtbj.cn

电话(Tel): 010-88724984 88749821

传真(Fax): 010-88715189

客服热线: 400-0330-789